

PERFORMANCE FOR 2006-07

Out of total 32 units, 5 units have achieved PLF above 90% , 4 units achieved PLF between 85 % to 90% & 4 units achieved PLF between 80% to 85% during the year 2006-07.

**Performance of Mahagenco Thermal units
(PLF between 90% to 100%) for 2006-07**

Sr. No.	Power Station	Unit No.	Gen. Cap. (MW)	Gen. (MU)	PLF (%)	AVF (%)	Loadability (%)	Avg Load Shared (MW)
1	Nasik	5	210	1693.659	92.07	97.84	94.10	198
2	Chandrapur	4	210	1661.849	90.34	94.46	95.64	201
3	Khaperkheda	1	210	1698.810	92.35	95.43	96.77	203
4		3	210	1706.798	92.78	94.12	98.58	207
5		4	210	1667.052	90.62	92.82	97.63	205

**Performance of Mahagenco Thermal units
(PLF between 85% to 90%) for 2006-07**

Sr. No.	Power Station	Unit No.	Gen. Cap. (MW)	Gen. (MU)	PLF (%)	AVF (%)	Loadability (%)	Avg Load Shared (MW)
1	Parli	1	30	227.778	86.67	91.01	95.24	29
2		2	30	230.172	87.58	91.27	95.96	29
3		5	210	1588.719	86.36	88.84	97.21	204
4	Chandrapur	3	210	1631.477	88.69	92.42	95.96	202

**Performance of Mahagenco Thermal units
(PLF between 80% to 85%) for 2006-07**

1	Nasik	3	210	1558.689	84.73	91.02	93.09	195
2		4	210	1553.856	84.47	91.70	92.11	193
3	Paras	2	58	425.026	83.65	91.27	91.65	53
4	Khaperkheda	2	210	1509.350	82.05	89.27	91.91	193