KORADI THERMAL POWER STATION, KORADI

Ash Generation & Utilization Data Category-wise Jun-16

| Coal Cons. (MT) | Ash (%) | Total Ash Generated (MT) | Ash Utilization category-wise (MT) | | | | Total Ash Utilised (MT) | Utilization % |
|--------------------|---------|--------------------------------|------------------------------------|-------------------|-----------|--------------------|----------------------------|---------------|
| | | | Dry Fly Ash (MT) | Wet Pond Ash (MT) | | | | |
| | | | | Bricks (MT) | Road (MT) | Total Wet Ash (MT) | 14500 | 22.59 |
| 157244 | 40.82% | 64187 | 0 | 14500 | 0 | 14500 | | |

Please publish the data on MAHAGENCO's website & share the same data on MPCB website as per their requirement & Fly Ash Utilization Notification-1999; amemded in 2003 & the mail by MPCB on Dtd.02.07.2014.

^{*} Remark: Unit-5 & 7 under Reserve Shut Down (RSD) and Unit-6 under R & M work.